

NOT to be distributed outside FACTORY MUTUAL SYSTEM, except by CLIENT.

SPECIFICATION TESTED PRODUCTS

LISTING REPORT

ASTM E-84 TEST RESULTS ON GENERAL PURPOSE PLASTIC LINER PANELS

Prepared For:

Stabilit S.A. de C.V.
HUMBERTO LOBO NO. 4317
COMPLEJO IND. MITRAS
VILLA de GARCIA N.L.C.P. 64000
MEXICO

3005799
Class 4820
Date: June 2, 2000
Supersedes Report Dated: October 18, 1999

FACTORY MUTUAL



Factory Mutual Research
1151 Boston-Providence Turnpike
P.O. Box 9102
Norwood, MA 02062



PRODUCT IDENTIFICATION MARKING

FACTORY MUTUAL RESEARCH
SPECIFICATION TESTED PER ASTM E-84 (98e) TEST METHOD
FM REPORT J.I. 3005799

STABILIT S.A. de C.V..
GENERAL PURPOSE PLASTIC LINER PANELS
0.060 - 0.090 IN. (1.5 - 2.3 MM) THICKNESS
8 - 12 OZ/FT² (340 - 468 G/M²) PANEL WEIGHT

FIRE TEST RESULTS**ASTM E-84 (98e)**

Flame Spread	145
Smoke Density	325

THESE NUMERICAL VALUES ARE NOT INTENDED TO REFLECT HAZARDS PRESENTED BY THIS MATERIAL UNDER ACTUAL FIRE CONDITIONS.

FACTORY MUTUAL RESEARCH AUDIT INSPECTION AND RE-EXAMINATION PROGRAM RELATED ONLY TO THE ABOVE.